



Dartmouth Fire District No. 3

140 Cross Road, North Dartmouth, MA 02747 • 508-994-6761 • Fax 508-990-3640

ARTICLE VII

Secure Access Key Box

- 7.1 Any building, other than residential structures with four or less units, which have a fire alarm system or other fire protection system, shall require a Secure Access Key Box. The key box shall be mounted at a location readily accessible to the fire department, closest to the main entrance of the structure. The key box shall contain keys to the fire alarm control panel, keys necessary to operate or service fire protection equipment, and keys to access all areas covered by the fire alarm or protection systems. The fire department is to be notified of any change with regard to keys contained within the key box and provided replacements in a timely manner.

05-01-06